

# 2024 Annual Drinking Water Quality Report

(Consumer Confidence Report)

## HEADWATERS AT BARTON CREEK

Phone No. (512) 246-1400

*Special Notice for the ELDERLY, INFANTS, CANCER PATIENTS, people with HIV/AIDS or other immune problems:*

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline at (800) 426-4791.

### Public Participation Opportunities

Please call (512) 246-1400 to confirm meeting dates and time. The Board of Directors generally meets on the third Thursday of each month at 12:00 pm at Freehold Capital Management located at 8601 RR 2222, Bldg.1, Ste. 260, Austin, TX. Please call (512) 328-2008 to confirm meeting dates and times.

The District's water system is operated by Crossroads Utility Services, LLC. If you have any questions concerning water quality or the source of your water, please call (512) 246-1400 or (512) 246-5905.

### Our Drinking Water Meets or Exceeds All Federal (EPA) Drinking Water Requirements

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

**WATER SOURCES:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment include: microbes, inorganic contaminants, pesticides, herbicides, radioactive contaminants, and organic chemical contaminants.

### *En Español*

Este informe incluye informacion importante sobre el agua potable. Si tiene preguntas o comentarios sobre este informe en español favor de llamar al tel. (512) 246-1400 para hablar con una persona bilingue en español.

## Where do we get our drinking water?

Our drinking water is supplied to you through the distribution system as owned by Headwaters M.U.D. (the District). The District purchases all of its water from the West Travis County Public Utility Agency, who obtains the water from Lake Austin. (Travis County) The PUA treats and filters the water from these sources according to federal and state standards, removing harmful contaminants. The sampling requirements for our water system are based on this susceptibility and previous sample data. Any detection of these contaminants will be found in this report. If we receive or purchase water from another system, their susceptibility will not be included in this report. For more information on source water assessments and protection efforts at our system, please contact us.

### ***ALL drinking water may contain contaminants.***

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

### **Secondary Constituents**

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concerns. Therefore, secondaries are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

## About the Following Pages

The pages that follow list all of the federally regulated or monitored contaminants which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants.

### **DEFINITIONS**

#### **Maximum Contaminant Level (MCL)**

The highest permissible level of a contaminant in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

#### **Maximum Contaminant Level Goal (MCLG)**

The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

#### **Maximum Residual Disinfectant Level (MRDL)**

The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

#### **Maximum Residual Disinfectant Level Goal (MRDLG)**

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

#### **Treatment Technique (TT)**

A required process intended to reduce the level of a contaminant in drinking water.

#### **Action Level (AL)**

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

### **ABBREVIATIONS**

NTU – Nephelometric Turbidity Units

MFL – million fibers per liter (a measure of asbestos)

pCi/L – picocuries per liter (a measure of radioactivity)

ppm – parts per million, or milligrams per liter (mg/L)

ppb – parts per billion, or micrograms per liter (µg/L)

ppt – parts per trillion, or nanograms per liter

ppq – parts per quadrillion, or picograms per liter

**Inorganic Contaminants**

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Source of Contaminant
2017	Asbestos (MFL)	<0.197	<0.197	<0.197	7	7	Decay of asbestos cement in water mains; erosion of natural deposits.
2024	Barium (ppm)	0.079	0.079	0.079	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
2023	Cyanide (ppb)	0.14	0.14	0.14	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories.
2024	Fluoride (ppm)	0.23	0.23	0.23	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
2024	Nickel (ppm)	0.0014	0.0014	0.0014	0.1	0.1	Abundant naturally occurring element.
2024	Nitrate* (ppm)	0.2	0.2	0.2	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
2017	Nitrite (ppm)	<0.01	<0.01	<0.01	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.

\*Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. If you are caring for an infant you should ask advice from your health care provider.

**Organic Contaminants**

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Source of Contaminant
2024	DI (2-Ethylhexyl Phthalate (ppb)	<0.6	<0.6	<0.6	6.0	0	Discharge from rubber and chemical factories.
2024	Simazene (ppb)	<0.07	<0.07	<0.07	4	4	Herbicide runoff.

**Volatile Organic Contaminants**

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Contaminant
2024	Vinyl Chloride	<0.5	<0.5	<0.5	2	ppb	Leaching from PVC piping; Discharge of plastic factories

**Maximum Residual Disinfectant Level**

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Source of Disinfectant
2024	Chloramines (ppm)	2.48	1.0	4.2	4.0	<4.0	Disinfectant used to control microbes

**Disinfection Byproducts**

Year	Contaminant	LR Annual Average	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Contaminant
2024	Total Haloacetic Acids	12.2	12.2	12.2	60	ppb	Byproduct of drinking water disinfection.
2024	Total Trihalomethanes	41.0	41.1	41.1	80	ppb	Byproduct of drinking water disinfection.

**Unregulated Initial Distribution System Evaluation for Disinfection Byproducts** WAIVED OR NOT YET SAMPLED**Unregulated Contaminants**

Bromoform, chloroform, bromodichloromethane, and dibromochloromethane are disinfection byproducts. There is no maximum contaminant level for these chemicals at the entry point to distribution.							
Year	Contaminant	Average Level	Minimum Level	Maximum Level		Unit of Measure	Source of Contaminant
2024	Chloroform	6.6	6.6	6.6		ppb	Byproduct of drinking water disinfection.
2024	Bromoform	4.6	4.6	4.6		ppb	Byproduct of drinking water disinfection.
2024	Bromodichloromethane	13.3	13.3	13.3		ppb	Byproduct of drinking water disinfection.
2024	Dibromochloromethane	16.6	16.6	16.6		ppb	Byproduct of drinking water disinfection.

**Lead and Copper**

Year	Contaminant	The 90 <sup>th</sup> Percentile	Number of Sites Exceeding Action Level	Action Level	Unit of Measure	Source of Contaminant
2022	Lead	0.000	0	15	ppb	Corrosion of household plumbing systems; erosion of natural deposits.
2022	Copper	0.040	0	1.3	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

<http://www.epa.gov/safewater/lead>".

**Turbidity**

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.					
Year	Contaminant	Highest Single Measurement	Lowest Monthly % of Samples Meeting Limits	Turbidity Limits	Source of Contaminant
2024	Turbidity (NTU)	0.6	95 %	0.3	Soil runoff.

**2024 Total Coliform:** REPORTED MONTHLY TESTS FOUND NO TOTAL COLIFORM BACTERIA

**2024 Fecal Coliform:** REPORTED MONTHLY TESTS FOUND NO FECAL COLIFORM BACTERIA

**Secondary and Other Constituents Not Regulated** (No associated adverse health effects)

Year	Contaminant	Average Level	Minimum Level	Maximum Level	Limit	Source of Contaminant
2024	Aluminum (ppm)	0.02	0.02	0.02	0.2	Abundant naturally occurring element.
2024	Bicarbonate (ppm)	184	184	184	NA	Corrosion of carbonate rocks such as limestone.
2024	Calcium (ppm)	37.6	37.6	37.6	NA	Abundant naturally occurring element.
2024	Chloride (ppm)	63	63	63	300	Abundant naturally occurring element; used in water purification; byproduct of oil field activity.
2024	Magnesium (ppm)	23.8	23.8	23.8	NA	Abundant naturally occurring element.
2024	Manganese (ppm)	0.001	0.001	0.001	0.05	Abundant naturally occurring element.
2018	pH (units)	7.5	7.5	7.6	7	Measure of corrosivity of water.
2024	Sodium (ppm)	32.5	32.5	32.5	NA	Erosion of natural deposits; byproduct of oil field activity.
2024	Sulfate (ppm)	32	32	32	300	Naturally occurring; common industrial byproduct; byproduct of oil field activity.
2024	Total Alkalinity as CaCO <sub>3</sub> (ppm)	158.4	136	164	NA	Naturally occurring soluble mineral salts.
2024	Total Dissolved Solids (ppm)	317	317	317	1000	Total dissolved mineral constituents in water.
2024	Total Hardness as CaCO <sub>3</sub> (ppm)	192	192	192	NA	Naturally occurring calcium.
2024	Zinc (ppm)	<0.005	<0.005	<0.005	5	Moderately abundant naturally occurring element; used in the metal industry.

**PWS 1050184**

**Lead Service Line Inventory Report**

<https://ccr.crossroadsus.com/lead/HeadwatersMUD-LeadCopperDetailedInventoryTCEQ.pdf>

